



Fire Department

500 West Big Beaver Road

Troy, Michigan 48084

Phone: 248-524-3419

Fax: 248-689-7520

FIRE LANES

Fire lanes are to be a minimum of 18 feet in width and a minimum of 14 feet in height.

Fire lane signs are to be installed and maintained in compliance with the criteria as set forth in the Michigan Manual of Uniform Traffic Control Devices.

Some of the criteria as set forth in the Michigan Manual of Uniform Traffic Control Devices is as follows:

1. Signs shall be red lettering on white background and shall read FIRE LANE – NO PARKING. NO STOPPING. NO STANDING. – TOW AWAY ZONE.
2. Signs shall be spaced no further than 100 feet apart.
3. Signs shall be installed at a right angle or 90⁰ to curb.
4. Signs shall be seven (7) feet from the bottom of sign to grade.
5. Signs shall be double faced where the possibility exists for left wheel to curb parking.
6. Signs shall be 12 inches in width and 18 inches in height.

A copy of the site plan showing fire lane locations as prescribed by the Troy Fire Department shall be submitted to the Fire Prevention Division on 8 ½" x 11" Printed format for Traffic Safety Committee review and recommendation to City Council for ultimate approval.

Any questions concerning this matter may be directed to the Troy Fire Department.

Thank you in advance for your cooperation.

FIRE LANE

**NO PARKING
NO STOPPING
NO STANDING**

**TOW AWAY
ZONE**